



classification, certification, inspection & testing

STATEMENT N° 201600189

Following to the request of Messrs. **Zelig Srl , P.zza Fontana 46, 74123 – Taranto (Italy)**

IT IS STATED THAT

The agent named **FireFive** produced by **Zelig Srl, P.zza Fontana 46, 74123 - Taranto (Italy)** can be used as an additive in the water based fire-fighting systems listed below to be used on board of all passenger ships, cargo ships, fishing vessels and yachts classed by RINA:

- Sprinkler systems for accommodation, service spaces and control stations other than those certified according to Res. A (800);
- Drencher systems for special category spaces other than those certified according to MSC.1/Circ. 1272

Drawings relevant to components and piping arrangement necessary to supply the agent to the fire-fighting systems are to be sent for approval for each single ship.

Genoa, April 26, 2016



Head of ITMA Section