

CERTIFICATE OF COMPLIANCE

Certificate Number 20160128-EX26849
Report Reference EX26849-20160128
Issue Date 2016-JANUARY-28

Issued to: ZELIG SRL
Via della Transumanza, 5
74123 Taranto TA ITALY

**This is to certify that
representative samples of**

WETTING AGENTS

Fire Five Encapsulator wetting agent concentrate, when added to water in concentrations of not less than 0.25% for Class A fires and not less than 2% for Class B fires.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: NFPA 18 - National Fire Protection Association Standard on Wetting

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

